

Year	Lead 90 <sup>th</sup> Percentile, mg/L	Copper 90 <sup>th</sup> Percentile, mg/L
2015	0.002	0.09
2012	0.002	0.49
2009	0.003	0.57
2008	0.008	0.52
2007	0.003	0.45
2006	0.004	0.58
2005	0.005	0.82

Notes;

1. Action limit per MassDEP is:
  - a. 0.010 mg/L for lead
  - b. 1.300 mg/L for copper
2. In 2009, the MassDEP approved a request from Wareham Water for monitoring every three years.